# St Louis Park Fire Inspection Report

## Fire Department Information

**Date Completed:** 09/10/2025
**Inspection Type:** Re-Inspection
**Inspector:** Hampton, Bob
**Shift:** Office Only
Administration 952-924-2595
**Unit:** U1 - U1
**Start Time:** 09/10/2025 09:00:00
**End Time:** 09/10/2025 09:54:36

## Building and Business information

**Name:** Helix -167 units
**Occupant Suite:**
**Occupant Number:** 7450
**Occupant Street :** HWY 7
**Street Type:** Highway
**Primary Contact First Name**
**Primary Contact Last Name**
**Primary Contact Email**

## Listing violations needing corrective action

**Violations**

| Violation Code | Category | Comments | Repaired Date | Documents |
|---|---|---|---|---|
| MNSFC 1003.6 | Means of Egress | No Personal belongings in hallways, including mats and decorations on doors<br><br>*UNRESOLVED 9/10/25 throughout building | 10/28/2025 14:21:28 | |
| MNSFC 1008 | Means of Egress | Adjust fire door to close and latch by units:<br>469<br>355<br><br>*UNRESOLVED 9/10/25 | 10/28/2025 14:21:35 | |
| MNSFC 2015 | All Chapters | Replace deteriorated or missing fire caulking in:<br>-storage room buy units 471<br>-Laundry room by unit 326<br>-Around sprinkler heads and wiring in mech room by 250 | 09/10/2025 09:23:35 | |
| MNSFC 2015 | All Chapters | Verify all garbage chute doors self close and latch. | 09/10/2025 09:23:42 | |
| 1011.1 | Egress - Signs Required (New) | Remove direction arrow in exit sign by unit 365. Arrow points to a wall. | 09/10/2025 09:21:14 | |
| MNSFC 1011.6.3 | Means of Egress | Verify all exit lights and emergency light have adequate back up battery power, to last 90 minutes.<br><br>*UNRESOLVED 9/10/25<br>H Stair 2nd Floor | 10/28/2025 14:21:41 | |
| MNSFC 901.6 | Fire Protection Systems | Missing smoke alarm in garage mech room | 10/28/2025 14:21:48 | |
| MNSFC 2015 | All Chapters | Adjust below grade gate to fully spring close | 09/10/2025 09:24:07 | |

**Violation Documents**

**File Name:** image
**Violation Code:** 1011.1
**Inspected Date:** 2025-06-25 08:42:51



**File Name:** image
**Violation Code:** MNSFC 2015
**Inspected Date:** 2025-06-25 09:21:22



## Inspection Notes

**Notes:**

**Passed:** No

## Signatures

**Signatures**

| First Name | Last Name | Signature Date |
|---|---|---|
| Bob | Hampton | 09/10/2025 |